

Report Filters			
From Date	23-Mar-2026	To Date	29-Mar-2026
Hospitals	EART TRAINING LAB		

Historical Alarms

1. Alarms & Notifications Summary of Device (987BF3ADB093)

Alarm Summary			
Parameter	Total Alarm Count	High Alarm Count	Low Alarm Count
Battery Level	4	0	4
Temp	4	0	4
pH Communication Failure	4	NA	NA
pH	4	0	4

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
0	0	16

Notification Summary						
Email Count	Push Count	SMS Count	Call Answered Count	Call UnAnswered Count	WhatsApp Count	Alexa Count
32	0	32	0	32	0	0

User Notification Summary							
User	Email Count	Push Count	SMS Count	Call Answered Count	Call UnAnswered Count	WhatsApp Count	Alexa Count
Valliappan S	16	0	16	0	16	0	0
Prasanna Venkatesan	16	0	16	0	16	0	0

2. Alarms & Notifications Summary of Device (Heracell150iIncubator)

Alarm Summary			
Parameter	Total Alarm Count	High Alarm Count	Low Alarm Count
Temp	4	0	4

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
4	0	0

ALARM & EVENTS

Notification Summary						
Email Count	Push Count	SMS Count	Call Answered Count	Call UnAnswered Count	WhatsApp Count	Alexa Count
8	0	8	0	8	0	0

User Notification Summary							
User	Email Count	Push Count	SMS Count	Call Answered Count	Call UnAnswered Count	WhatsApp Count	Alexa Count
Valliappan S	4	0	4	0	4	0	0
Prasanna Venkatesan	4	0	4	0	4	0	0

Shivani Scientific

987BF3ADB093

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	987BF3ADB093	pH Battery Level Low	3/26/2026 9:01:49 AM	3/31/2026 11:39:01 AM	122:37:12	0	60	100	20
EART TRAINING LAB	987BF3ADB093	Temp Low	3/26/2026 9:01:49 AM	3/31/2026 11:39:01 AM	122:37:12	0	37	38.35	35.65
EART TRAINING LAB	987BF3ADB093	pH Communication Failure	3/26/2026 9:01:49 AM	NA	146:47:22	NA	NA	NA	NA
EART TRAINING LAB	987BF3ADB093	pH Low	3/26/2026 9:01:49 AM	NA	146:47:22	0	7.3	7.8	6.8
EART TRAINING LAB	987BF3ADB093	pH Communication Failure	3/25/2026 10:01:10 AM	NA	169:48:01	NA	NA	NA	NA
EART TRAINING LAB	987BF3ADB093	pH Low	3/25/2026 10:01:09 AM	NA	169:48:02	0	7.3	7.8	6.8
EART TRAINING LAB	987BF3ADB093	Temp Low	3/25/2026 10:01:09 AM	3/31/2026 11:39:01 AM	145:37:52	0	37	38.35	35.65
EART TRAINING LAB	987BF3ADB093	pH Battery Level Low	3/25/2026 10:01:09 AM	3/31/2026 11:39:01 AM	145:37:52	0	60	100	20
EART TRAINING LAB	987BF3ADB093	pH Communication Failure	3/24/2026 9:33:29 AM	NA	194:15:42	NA	NA	NA	NA
EART TRAINING LAB	987BF3ADB093	pH Low	3/24/2026 9:33:28 AM	NA	194:15:43	0	7.3	7.8	6.8
EART TRAINING LAB	987BF3ADB093	Temp Low	3/24/2026 9:33:28 AM	3/31/2026 11:39:01 AM	170:05:33	0	37	38.35	35.65
EART TRAINING LAB	987BF3ADB093	pH Battery Level Low	3/24/2026 9:33:28 AM	3/31/2026 11:39:01 AM	170:05:33	0	60	100	20
EART TRAINING LAB	987BF3ADB093	Temp Low	3/23/2026 9:06:57 AM	3/31/2026 11:39:01 AM	194:32:04	0	37	38.35	35.65
EART TRAINING LAB	987BF3ADB093	pH Communication Failure	3/23/2026 9:06:57 AM	NA	218:42:14	NA	NA	NA	NA
EART TRAINING LAB	987BF3ADB093	pH Battery Level Low	3/23/2026 9:06:57 AM	3/31/2026 11:39:01 AM	194:32:04	0	60	100	20
EART TRAINING LAB	987BF3ADB093	pH Low	3/23/2026 9:06:57 AM	NA	218:42:14	0	7.3	7.8	6.8

Heracell150iIncubator

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Heracell150Incu bator	Temp Low (Orange)	3/26/2026 9:01:49 AM	3/26/2026 9:31:50 AM	00:30:01	28.54	37	37.5	36.5
EART TRAINING LAB	Heracell150Incu bator	Temp Low (Orange)	3/25/2026 10:01:09 AM	3/25/2026 10:31:36 AM	00:30:27	28.15	37	37.5	36.5
EART TRAINING LAB	Heracell150Incu bator	Temp Low (Orange)	3/24/2026 9:33:28 AM	3/24/2026 10:03:30 AM	00:30:02	28.3	37	37.5	36.5
EART TRAINING LAB	Heracell150Incu bator	Temp Low (Orange)	3/23/2026 9:06:57 AM	3/23/2026 9:35:44 AM	00:28:47	29.31	37	37.5	36.5

Historical Events

1. Events of Device (LabDoor)

Events Summary	
Events	Total Count
Door Open	14
Door Communication Error	1

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
15	0	0

2. Events of Device (NLH1004)

Events Summary	
Events	Total Count
Sensor Disconnected	79
CO2/Temp/rH Sensor Failure	55
VOC Sensor Failure	1

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
126	4	5

3. Events of Device (NOS102)

Events Summary	
Events	Total Count
O2 Low	10
Temp Low	1

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
11	0	0

4. Events of Device (AstecEC6Incubator)

Events Summary	
Events	Total Count
CO2 Low	5
Temp 5 Low (Orange)	1

Events Summary	
Temp 1 Low (Red)	1
Temp 3 Low (Orange)	1
Temp 6 Low (Orange)	1
O2 Low	1
Temp 4 Low (Orange)	1
Temp 2 Low (Orange)	1

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
12	0	0

5. Events of Device (Door3)

Events Summary	
Events	Total Count
Door Communication Error	10
Door-4 Battery Level Low	1

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
11	0	0

6. Events of Device (Door5)

Events Summary	
Events	Total Count
Door Communication Error	9

Events Summary	
Door-5 Battery Level Low	1

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
10	0	0

7. Events of Device (Door1)

Events Summary	
Events	Total Count
Door Communication Error	18
Door-1 Battery Level Low	1
Door Communication Error	87

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
106	0	0

8. Events of Device (Door6)

Events Summary	
Events	Total Count
Door Communication Error	3

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes

Turn Around Summary		
3	0	0

9. Events of Device (Door2)

Events Summary	
Events	Total Count
Door Communication Error	1
Door-2 Battery Level Low	1

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
2	0	0

10. Events of Device (Heracell150Incubator)

Events Summary	
Events	Total Count
WaterLevel Low	4
CO2 Low	4

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
4	0	4

11. Events of Device (AstecEC10Incubator)

Events Summary	
Events	Total Count
CO2 Low	13
O2 High	9

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
22	0	0

12. Events of Device (Temp2)

Events Summary	
Events	Total Count
Sensor Communication Failure	6

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
6	0	0

13. Events of Device (Temp)

Events Summary	
Events	Total Count
Sensor Communication Failure	81
Temp Low	37

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
113	1	4

14. Events of Device (Temp1)

Events Summary	
Events	Total Count
Temp High	133

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
133	0	0

15. Events of Device (ASNC02 Vaishala)

Events Summary	
Events	Total Count
CO2 High	7

Turn Around Summary		
Turn Around time < 30 Minutes	Turn Around time > 30 Minutes and < 60 Minutes	Turn Around time > 60 Minutes
4	1	2

LabDoor

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	LabDoor	Door Open	3/26/2026 6:02:55 PM	3/26/2026 6:03:02 PM	00:00:07	1	0	2	0
EART TRAINING LAB	LabDoor	Door Communication Error	3/26/2026 3:27:03 PM	3/26/2026 3:28:43 PM	00:01:40	NA	NA	NA	NA
EART TRAINING LAB	LabDoor	Door Open	3/26/2026 12:49:51 PM	3/26/2026 12:52:40 PM	00:02:49	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/26/2026 9:36:51 AM	3/26/2026 9:36:57 AM	00:00:06	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/26/2026 9:36:12 AM	3/26/2026 9:36:19 AM	00:00:07	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/25/2026 5:57:25 PM	3/25/2026 5:57:31 PM	00:00:06	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/24/2026 6:28:24 PM	3/24/2026 6:28:31 PM	00:00:07	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/24/2026 9:43:17 AM	3/24/2026 9:43:23 AM	00:00:06	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/24/2026 9:42:20 AM	3/24/2026 9:42:27 AM	00:00:07	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/23/2026 5:56:04 PM	3/23/2026 5:56:10 PM	00:00:06	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/23/2026 2:09:11 PM	3/23/2026 2:09:19 PM	00:00:08	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/23/2026 2:07:38 PM	3/23/2026 2:07:46 PM	00:00:08	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/23/2026 9:47:39 AM	3/23/2026 9:47:45 AM	00:00:06	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/23/2026 9:46:40 AM	3/23/2026 9:46:47 AM	00:00:07	1	0	2	0
EART TRAINING LAB	LabDoor	Door Open	3/23/2026 9:32:38 AM	3/23/2026 9:32:44 AM	00:00:06	1	0	2	0

NLH1004

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 5:42:56 PM	3/26/2026 5:42:56 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 5:42:54 PM	3/26/2026 5:42:54 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 5:42:54 PM	3/26/2026 5:42:59 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 5:26:59 PM	3/26/2026 5:26:59 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 5:26:59 PM	3/26/2026 5:27:04 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 4:54:26 PM	3/26/2026 4:54:26 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 4:54:26 PM	3/26/2026 4:54:31 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 3:28:21 PM	3/26/2026 3:28:43 PM	00:00:22	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 3:27:56 PM	3/26/2026 3:28:21 PM	00:00:25	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 3:27:10 PM	3/26/2026 3:27:31 PM	00:00:21	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 3:23:51 PM	3/26/2026 3:23:51 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 3:23:51 PM	3/26/2026 3:23:56 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 2:50:31 PM	3/26/2026 2:50:35 PM	00:00:04	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 2:50:31 PM	3/26/2026 2:50:31 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 2:23:28 PM	3/26/2026 2:23:33 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 1:39:11 PM	3/26/2026 1:39:11 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 1:39:11 PM	3/26/2026 1:39:16 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 1:39:11 PM	3/26/2026 2:23:28 PM	00:44:17	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 12:11:27 PM	3/26/2026 12:11:32 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 12:03:07 PM	3/26/2026 12:03:07 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 12:02:56 PM	3/26/2026 12:11:27 PM	00:08:31	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 11:51:20 AM	3/26/2026 11:51:20 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 11:51:20 AM	3/26/2026 11:51:20 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 11:51:15 AM	3/26/2026 12:03:07 PM	00:11:52	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 11:50:01 AM	3/26/2026 11:50:01 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 11:50:01 AM	3/26/2026 11:50:06 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 11:50:01 AM	3/26/2026 11:50:01 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 11:45:42 AM	3/26/2026 11:45:42 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 11:45:42 AM	3/26/2026 11:45:47 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 10:25:01 AM	3/26/2026 10:25:01 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 10:25:01 AM	3/26/2026 10:25:01 AM	00:00:00	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 10:25:01 AM	3/26/2026 10:25:06 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 10:22:08 AM	3/26/2026 10:22:13 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 9:17:08 AM	3/26/2026 9:17:08 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 9:17:08 AM	3/26/2026 9:17:08 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 9:17:03 AM	3/26/2026 10:22:08 AM	01:05:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 9:07:17 AM	3/26/2026 9:07:22 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 9:07:17 AM	3/26/2026 9:07:17 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/26/2026 9:04:42 AM	3/26/2026 9:04:47 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 9:04:42 AM	3/26/2026 9:04:42 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/26/2026 9:02:06 AM	3/26/2026 9:02:21 AM	00:00:15	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 5:26:11 PM	3/25/2026 5:26:11 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 5:26:11 PM	3/25/2026 5:26:16 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 5:08:37 PM	3/25/2026 5:08:37 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 5:08:37 PM	3/25/2026 5:08:37 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 3:45:26 PM	3/25/2026 3:51:37 PM	00:06:11	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 3:24:35 PM	3/25/2026 3:24:35 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 3:10:42 PM	3/25/2026 3:10:42 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 3:10:41 PM	3/25/2026 3:24:40 PM	00:13:59	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 2:57:52 PM	3/25/2026 2:57:52 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 2:57:52 PM	3/25/2026 2:57:52 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 2:38:17 PM	3/25/2026 2:38:17 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 2:38:17 PM	3/25/2026 2:38:17 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 1:44:34 PM	3/25/2026 1:44:39 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 1:44:34 PM	3/25/2026 1:44:34 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 1:15:23 PM	3/25/2026 1:15:23 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 1:15:23 PM	3/25/2026 1:15:28 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 12:52:54 PM	3/25/2026 12:52:54 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 12:30:42 PM	3/25/2026 12:30:42 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 12:30:42 PM	3/25/2026 12:30:42 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 12:30:37 PM	3/25/2026 12:52:59 PM	00:22:22	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 12:02:01 PM	3/25/2026 12:02:01 PM	00:00:00	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 10:53:28 AM	3/25/2026 10:53:28 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 10:53:23 AM	3/25/2026 12:02:01 PM	01:08:38	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/25/2026 10:05:34 AM	3/25/2026 10:05:34 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 10:05:29 AM	3/25/2026 10:53:28 AM	00:47:59	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/25/2026 10:01:07 AM	3/25/2026 10:01:12 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 6:09:59 PM	3/24/2026 6:09:59 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 6:09:58 PM	3/24/2026 6:10:03 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 6:09:58 PM	3/24/2026 6:09:58 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 5:39:26 PM	3/24/2026 5:39:26 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 5:39:26 PM	3/24/2026 5:39:31 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 5:30:32 PM	3/24/2026 5:30:37 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 5:28:45 PM	3/24/2026 5:28:45 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 5:28:44 PM	3/24/2026 5:28:48 PM	00:00:04	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 5:28:43 PM	3/24/2026 5:30:32 PM	00:01:49	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 5:01:25 PM	3/24/2026 5:01:25 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 5:01:25 PM	3/24/2026 5:01:30 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 3:57:19 PM	3/24/2026 3:57:24 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 3:57:19 PM	3/24/2026 3:57:19 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 3:53:35 PM	3/24/2026 3:53:35 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 3:53:35 PM	3/24/2026 3:53:40 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 2:41:34 PM	3/24/2026 2:41:34 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 2:41:34 PM	3/24/2026 2:41:39 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 2:19:22 PM	3/24/2026 2:19:27 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 2:19:22 PM	3/24/2026 2:19:22 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 2:10:04 PM	3/24/2026 2:10:09 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 2:10:04 PM	3/24/2026 2:10:04 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 1:51:07 PM	3/24/2026 1:51:07 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 1:51:07 PM	3/24/2026 1:51:12 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 1:45:05 PM	3/24/2026 1:45:05 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 1:45:05 PM	3/24/2026 1:45:10 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 1:00:48 PM	3/24/2026 1:00:48 PM	00:00:00	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 1:00:44 PM	3/24/2026 1:00:44 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 1:00:44 PM	3/24/2026 1:00:49 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 12:42:31 PM	3/24/2026 12:42:31 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 12:42:31 PM	3/24/2026 12:42:36 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 12:31:30 PM	3/24/2026 12:31:30 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 12:31:30 PM	3/24/2026 12:31:35 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 12:28:38 PM	3/24/2026 12:28:38 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 12:28:38 PM	3/24/2026 12:28:43 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 10:57:38 AM	3/24/2026 10:57:43 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 10:57:38 AM	3/24/2026 10:57:38 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 10:40:24 AM	3/24/2026 10:40:24 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/24/2026 10:40:24 AM	3/24/2026 10:40:29 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 9:35:24 AM	3/24/2026 10:35:02 AM	00:59:38	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 9:34:34 AM	3/24/2026 9:34:59 AM	00:00:25	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 9:34:09 AM	3/24/2026 9:34:34 AM	00:00:25	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 9:33:44 AM	3/24/2026 9:34:09 AM	00:00:25	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/24/2026 9:33:24 AM	3/24/2026 9:33:44 AM	00:00:20	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 4:58:55 PM	3/23/2026 4:58:55 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 4:58:54 PM	3/23/2026 5:56:13 PM	00:57:19	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 4:58:49 PM	3/24/2026 10:35:07 AM	17:36:18	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 4:56:37 PM	3/23/2026 4:56:37 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 4:56:37 PM	3/23/2026 4:56:42 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 3:59:17 PM	3/23/2026 3:59:17 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 3:59:17 PM	3/23/2026 3:59:22 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	VOC Sensor Failure	3/23/2026 3:34:27 PM	3/31/2026 10:22:31 AM	186:48:04	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 3:34:27 PM	3/23/2026 3:34:27 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 1:36:53 PM	3/23/2026 1:36:53 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 12:22:42 PM	3/23/2026 1:36:58 PM	01:14:16	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 12:22:42 PM	3/23/2026 12:22:42 PM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 11:37:52 AM	3/23/2026 11:37:57 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 11:34:42 AM	3/23/2026 11:34:42 AM	00:00:00	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 11:34:42 AM	3/23/2026 11:34:42 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 11:34:37 AM	3/23/2026 11:37:52 AM	00:03:15	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 11:33:51 AM	3/23/2026 11:33:56 AM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 11:33:51 AM	3/23/2026 11:33:51 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 11:33:51 AM	3/23/2026 11:33:51 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 11:23:25 AM	3/23/2026 11:23:25 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 9:48:07 AM	3/23/2026 9:48:07 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 9:48:07 AM	3/23/2026 9:48:10 AM	00:00:03	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 9:26:23 AM	3/23/2026 9:26:23 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	Sensor Disconnected	3/23/2026 9:26:22 AM	3/23/2026 9:26:22 AM	00:00:00	NA	NA	NA	NA
EART TRAINING LAB	NLH1004	CO2/Temp/rH Sensor Failure	3/23/2026 9:26:22 AM	3/23/2026 9:26:27 AM	00:00:05	NA	NA	NA	NA

NOS102

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	NOS102	O2 Low	3/26/2026 12:08:32 PM	3/26/2026 12:08:57 PM	00:00:25	1	19	21	17
EART TRAINING LAB	NOS102	O2 Low	3/25/2026 3:13:42 PM	3/25/2026 3:14:07 PM	00:00:25	1	19	21	17
EART TRAINING LAB	NOS102	O2 Low	3/25/2026 12:51:37 PM	3/25/2026 12:52:02 PM	00:00:25	1	19	21	17
EART TRAINING LAB	NOS102	O2 Low	3/24/2026 4:36:02 PM	3/24/2026 4:36:26 PM	00:00:24	1	19	21	17
EART TRAINING LAB	NOS102	O2 Low	3/24/2026 10:10:37 AM	3/24/2026 10:11:02 AM	00:00:25	1	19	21	17
EART TRAINING LAB	NOS102	O2 Low	3/23/2026 5:41:06 PM	3/23/2026 5:41:31 PM	00:00:25	1	19	21	17
EART TRAINING LAB	NOS102	O2 Low	3/23/2026 3:42:47 PM	3/23/2026 3:43:12 PM	00:00:25	1	19	21	17
EART TRAINING LAB	NOS102	O2 Low	3/23/2026 3:06:06 PM	3/23/2026 3:06:31 PM	00:00:25	1	19	21	17

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	NOS102	Temp Low	3/23/2026 11:31:07 AM	3/23/2026 11:31:32 AM	00:00:25	2	24	32	16
EART TRAINING LAB	NOS102	O2 Low	3/23/2026 11:24:02 AM	3/23/2026 11:24:27 AM	00:00:25	1	19	21	17
EART TRAINING LAB	NOS102	O2 Low	3/23/2026 10:29:51 AM	3/23/2026 10:30:16 AM	00:00:25	1	19	21	17

AstecEC6Incubator

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	AstecEC6Incubator	CO2 Low	3/25/2026 10:09:07 AM	3/25/2026 10:09:32 AM	00:00:25	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC6Incubator	CO2 Low	3/25/2026 10:08:17 AM	3/25/2026 10:08:42 AM	00:00:25	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC6Incubator	CO2 Low	3/23/2026 9:16:06 AM	3/23/2026 9:16:31 AM	00:00:25	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC6Incubator	CO2 Low	3/23/2026 9:14:01 AM	3/23/2026 9:14:26 AM	00:00:25	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC6Incubator	Temp 5 Low (Orange)	3/23/2026 9:06:47 AM	3/23/2026 9:17:22 AM	00:10:35	29.3	37	37.5	36.5
EART TRAINING LAB	AstecEC6Incubator	Temp 1 Low (Red)	3/23/2026 9:06:47 AM	3/23/2026 9:19:52 AM	00:13:05	29.4	37	37.5	36.5
EART TRAINING LAB	AstecEC6Incubator	Temp 3 Low (Orange)	3/23/2026 9:06:47 AM	3/23/2026 9:19:52 AM	00:13:05	29.3	37	37.5	36.5
EART TRAINING LAB	AstecEC6Incubator	Temp 6 Low (Orange)	3/23/2026 9:06:47 AM	3/23/2026 9:18:37 AM	00:11:50	29.3	37	37.5	36.5
EART TRAINING LAB	AstecEC6Incubator	O2 Low	3/23/2026 9:06:47 AM	3/23/2026 9:14:26 AM	00:07:39	0	5	5.5	4.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	AstecEC6Incubator	Temp 4 Low (Orange)	3/23/2026 9:06:47 AM	3/23/2026 9:18:37 AM	00:11:50	29.3	37	37.5	36.5
EART TRAINING LAB	AstecEC6Incubator	CO2 Low	3/23/2026 9:06:47 AM	3/23/2026 9:13:36 AM	00:06:49	3.5	6	6.5	5.5
EART TRAINING LAB	AstecEC6Incubator	Temp 2 Low (Orange)	3/23/2026 9:06:47 AM	3/23/2026 9:19:02 AM	00:12:15	29.4	37	37.5	36.5

Door3

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door3	Door Communication Error	3/24/2026 12:48:08 PM	3/24/2026 12:48:21 PM	00:00:13	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 1:28:02 PM	3/23/2026 1:28:12 PM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 1:27:17 PM	3/23/2026 1:27:32 PM	00:00:15	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 1:23:43 PM	3/23/2026 1:24:09 PM	00:00:26	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 1:16:03 PM	3/23/2026 1:16:14 PM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 1:13:04 PM	3/23/2026 1:13:26 PM	00:00:22	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 1:10:50 PM	3/23/2026 1:10:59 PM	00:00:09	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 1:06:21 PM	3/23/2026 1:06:37 PM	00:00:16	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 1:02:47 PM	3/23/2026 1:03:11 PM	00:00:24	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door Communication Error	3/23/2026 9:06:59 AM	3/23/2026 9:08:11 AM	00:01:12	NA	NA	NA	NA
EART TRAINING LAB	Door3	Door-4 Battery Level Low	3/23/2026 9:06:47 AM	3/23/2026 9:08:11 AM	00:01:24	0	70	105	35

Door5

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 1:30:54 PM	3/23/2026 1:31:03 PM	00:00:09	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 1:30:14 PM	3/23/2026 1:30:24 PM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 1:29:34 PM	3/23/2026 1:29:44 PM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 1:27:00 PM	3/23/2026 1:27:27 PM	00:00:27	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 1:18:54 PM	3/23/2026 1:19:05 PM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 1:18:13 PM	3/23/2026 1:18:24 PM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 1:15:15 PM	3/23/2026 1:15:26 PM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 1:12:33 PM	3/23/2026 1:13:09 PM	00:00:36	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door Communication Error	3/23/2026 9:06:59 AM	3/23/2026 9:08:21 AM	00:01:22	NA	NA	NA	NA
EART TRAINING LAB	Door5	Door-5 Battery Level Low	3/23/2026 9:06:47 AM	3/23/2026 9:08:21 AM	00:01:34	0	70	105	35

Door1

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:29:41 PM	3/23/2026 1:30:04 PM	00:00:23	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:28:19 PM	3/23/2026 1:28:38 PM	00:00:19	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:27:35 PM	3/23/2026 1:27:49 PM	00:00:14	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:24:41 PM	3/23/2026 1:24:59 PM	00:00:18	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:20:52 PM	3/23/2026 1:21:02 PM	00:00:10	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:19:41 PM	3/23/2026 1:19:51 PM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:17:54 PM	3/23/2026 1:18:04 PM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:16:04 PM	3/23/2026 1:16:17 PM	00:00:13	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:14:00 PM	3/23/2026 1:14:31 PM	00:00:31	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:13:21 PM	3/23/2026 1:13:30 PM	00:00:09	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:12:32 PM	3/23/2026 1:12:48 PM	00:00:16	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:11:31 PM	3/23/2026 1:12:01 PM	00:00:30	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:10:49 PM	3/23/2026 1:11:01 PM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:09:49 PM	3/23/2026 1:10:22 PM	00:00:33	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:05:33 PM	3/23/2026 1:06:06 PM	00:00:33	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:04:40 PM	3/23/2026 1:05:03 PM	00:00:23	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:04:01 PM	3/23/2026 1:04:10 PM	00:00:09	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 9:06:58 AM	3/23/2026 9:08:16 AM	00:01:18	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door-1 Battery Level Low	3/23/2026 9:06:47 AM	3/23/2026 9:08:16 AM	00:01:29	0	70	105	35
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:47:52 AM	3/26/2026 10:48:03 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:47:02 AM	3/26/2026 10:47:22 AM	00:00:20	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:45:58 AM	3/26/2026 10:46:31 AM	00:00:33	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:45:06 AM	3/26/2026 10:45:28 AM	00:00:22	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:43:42 AM	3/26/2026 10:43:54 AM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:42:26 AM	3/26/2026 10:42:40 AM	00:00:14	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:41:24 AM	3/26/2026 10:41:56 AM	00:00:32	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:40:40 AM	3/26/2026 10:40:54 AM	00:00:14	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:39:51 AM	3/26/2026 10:40:10 AM	00:00:19	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:39:03 AM	3/26/2026 10:39:17 AM	00:00:14	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:38:23 AM	3/26/2026 10:38:33 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:37:21 AM	3/26/2026 10:37:53 AM	00:00:32	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:36:40 AM	3/26/2026 10:36:51 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:35:57 AM	3/26/2026 10:36:10 AM	00:00:13	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:35:16 AM	3/26/2026 10:35:27 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:34:35 AM	3/26/2026 10:34:46 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:32:20 AM	3/26/2026 10:32:30 AM	00:00:10	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:31:35 AM	3/26/2026 10:31:47 AM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:30:55 AM	3/26/2026 10:31:05 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:27:47 AM	3/26/2026 10:28:10 AM	00:00:23	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:27:05 AM	3/26/2026 10:27:17 AM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:25:44 AM	3/26/2026 10:26:05 AM	00:00:21	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:24:11 AM	3/26/2026 10:24:43 AM	00:00:32	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:23:23 AM	3/26/2026 10:23:41 AM	00:00:18	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:22:42 AM	3/26/2026 10:22:53 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:21:58 AM	3/26/2026 10:22:12 AM	00:00:14	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:20:13 AM	3/26/2026 10:20:24 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:19:26 AM	3/26/2026 10:19:43 AM	00:00:17	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:18:02 AM	3/26/2026 10:18:20 AM	00:00:18	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:17:15 AM	3/26/2026 10:17:32 AM	00:00:17	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:16:05 AM	3/26/2026 10:16:44 AM	00:00:39	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:15:17 AM	3/26/2026 10:15:35 AM	00:00:18	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:14:30 AM	3/26/2026 10:14:47 AM	00:00:17	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:13:15 AM	3/26/2026 10:13:27 AM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:12:34 AM	3/26/2026 10:12:45 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:10:51 AM	3/26/2026 10:10:59 AM	00:00:08	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:10:09 AM	3/26/2026 10:10:21 AM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:08:56 AM	3/26/2026 10:09:07 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:06:41 AM	3/26/2026 10:06:52 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:04:37 AM	3/26/2026 10:05:07 AM	00:00:30	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:03:54 AM	3/26/2026 10:04:07 AM	00:00:13	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:01:47 AM	3/26/2026 10:02:02 AM	00:00:15	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 10:00:50 AM	3/26/2026 10:01:17 AM	00:00:27	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:58:33 AM	3/26/2026 9:58:43 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:56:47 AM	3/26/2026 9:56:56 AM	00:00:09	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:54:40 AM	3/26/2026 9:55:09 AM	00:00:29	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:54:01 AM	3/26/2026 9:54:10 AM	00:00:09	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:53:19 AM	3/26/2026 9:53:29 AM	00:00:10	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:52:38 AM	3/26/2026 9:52:49 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:51:55 AM	3/26/2026 9:52:07 AM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:51:16 AM	3/26/2026 9:51:25 AM	00:00:09	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:49:44 AM	2/2/2026 9:33:54 AM	-1248:-15:-50	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:49:04 AM	3/26/2026 9:49:14 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:48:20 AM	3/26/2026 9:48:34 AM	00:00:14	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:47:32 AM	3/26/2026 9:47:50 AM	00:00:18	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:45:25 AM	3/26/2026 9:45:58 AM	00:00:33	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:44:44 AM	3/26/2026 9:44:55 AM	00:00:11	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:44:05 AM	3/26/2026 9:44:14 AM	00:00:09	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:43:11 AM	3/26/2026 9:43:35 AM	00:00:24	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:41:28 AM	3/26/2026 9:41:38 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:40:45 AM	3/26/2026 9:40:58 AM	00:00:13	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:38:39 AM	3/26/2026 9:39:08 AM	00:00:29	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:37:56 AM	3/26/2026 9:38:09 AM	00:00:13	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:35:36 AM	3/26/2026 9:35:51 AM	00:00:15	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:34:46 AM	3/26/2026 9:35:05 AM	00:00:19	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:31:56 AM	3/26/2026 9:32:08 AM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:31:07 AM	3/26/2026 9:31:26 AM	00:00:19	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:30:17 AM	3/26/2026 9:30:37 AM	00:00:20	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:29:35 AM	3/26/2026 9:29:47 AM	00:00:12	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:28:55 AM	3/26/2026 9:29:05 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:28:06 AM	3/26/2026 9:28:25 AM	00:00:19	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:27:07 AM	3/26/2026 9:27:36 AM	00:00:29	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:25:48 AM	3/26/2026 9:26:06 AM	00:00:18	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:24:32 AM	3/26/2026 9:24:47 AM	00:00:15	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:23:52 AM	3/26/2026 9:24:02 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:09:25 AM	3/26/2026 9:09:35 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:08:41 AM	3/26/2026 9:08:55 AM	00:00:14	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:08:01 AM	3/26/2026 9:08:11 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:07:22 AM	3/26/2026 9:07:31 AM	00:00:09	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:06:42 AM	3/26/2026 9:06:52 AM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:05:45 AM	3/26/2026 9:06:11 AM	00:00:26	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/26/2026 9:04:57 AM	3/26/2026 9:05:15 AM	00:00:18	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/25/2026 12:24:43 PM	3/25/2026 12:24:56 PM	00:00:13	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/25/2026 12:23:27 PM	3/25/2026 12:23:41 PM	00:00:14	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/25/2026 10:01:52 AM	3/25/2026 10:01:53 AM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/24/2026 10:40:55 AM	3/24/2026 10:41:38 AM	00:00:43	NA	NA	NA	NA
EART TRAINING LAB	Door1	Door Communication Error	3/23/2026 1:02:04 PM	3/23/2026 1:02:15 PM	00:00:11	NA	NA	NA	NA

Door6

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door6	Door Communication Error	3/23/2026 1:28:12 PM	3/23/2026 1:28:34 PM	00:00:22	NA	NA	NA	NA
EART TRAINING LAB	Door6	Door Communication Error	3/23/2026 1:15:59 PM	3/23/2026 1:16:09 PM	00:00:10	NA	NA	NA	NA
EART TRAINING LAB	Door6	Door Communication Error	3/23/2026 1:04:17 PM	3/23/2026 1:04:27 PM	00:00:10	NA	NA	NA	NA

Door2

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Door2	Door Communication Error	3/23/2026 9:06:59 AM	3/23/2026 9:09:13 AM	00:02:14	NA	NA	NA	NA
EART TRAINING LAB	Door2	Door-2 Battery Level Low	3/23/2026 9:06:47 AM	3/23/2026 9:09:13 AM	00:02:26	0	70	105	35

Heracell150iIncubator

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Heracell150iIncubator	WaterLevel Low	3/26/2026 9:01:49 AM	NA	146:47:26	1	6	6.5	5.5
EART TRAINING LAB	Heracell150iIncubator	CO2 Low	3/26/2026 9:01:49 AM	3/26/2026 9:02:15 AM	00:00:26	5.45	6	6.5	5.5
EART TRAINING LAB	Heracell150iIncubator	WaterLevel Low	3/25/2026 10:01:09 AM	NA	169:48:06	1	6	6.5	5.5
EART TRAINING LAB	Heracell150iIncubator	CO2 Low (Red)	3/25/2026 10:01:09 AM	3/25/2026 10:01:35 AM	00:00:26	5.39	6	6.5	5.5
EART TRAINING LAB	Heracell150iIncubator	WaterLevel Low	3/24/2026 9:33:28 AM	NA	194:15:47	1	6	6.5	5.5
EART TRAINING LAB	Heracell150iIncubator	CO2 Low (Red)	3/24/2026 9:33:28 AM	3/24/2026 9:33:54 AM	00:00:26	5.43	6	6.5	5.5
EART TRAINING LAB	Heracell150iIncubator	CO2 Low	3/23/2026 9:06:57 AM	3/23/2026 9:08:13 AM	00:01:16	3.89	6	6.5	5.5
EART TRAINING LAB	Heracell150iIncubator	WaterLevel Low	3/23/2026 9:06:57 AM	NA	218:42:18	1	6	6.5	5.5

AstecEC10Incubator

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/26/2026 9:11:02 AM	3/26/2026 9:11:52 AM	00:00:50	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/26/2026 9:08:32 AM	3/26/2026 9:10:37 AM	00:02:05	5.4	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/26/2026 9:06:52 AM	3/26/2026 9:08:07 AM	00:01:15	5.2	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/26/2026 9:06:27 AM	3/26/2026 9:06:52 AM	00:00:25	5.5	5	5.5	4.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/25/2026 10:09:57 AM	3/25/2026 10:10:22 AM	00:00:25	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/25/2026 10:07:02 AM	3/25/2026 10:07:52 AM	00:00:50	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/25/2026 10:06:37 AM	3/25/2026 10:07:02 AM	00:00:25	5.6	5	5.5	4.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/25/2026 10:06:12 AM	3/25/2026 10:06:37 AM	00:00:25	5.4	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/25/2026 10:05:22 AM	3/25/2026 10:05:47 AM	00:00:25	5.2	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/25/2026 10:04:57 AM	3/25/2026 10:05:22 AM	00:00:25	5.5	5	5.5	4.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/24/2026 9:40:11 AM	3/24/2026 9:41:01 AM	00:00:50	5.5	5	5.5	4.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/24/2026 9:39:21 AM	3/24/2026 9:39:46 AM	00:00:25	5.3	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/24/2026 9:38:56 AM	3/24/2026 9:39:21 AM	00:00:25	5.6	5	5.5	4.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/24/2026 9:38:31 AM	3/24/2026 9:38:56 AM	00:00:25	5.1	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/24/2026 9:37:41 AM	3/24/2026 9:38:06 AM	00:00:25	5.5	5	5.5	4.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/23/2026 9:18:37 AM	3/23/2026 9:19:02 AM	00:00:25	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/23/2026 9:17:47 AM	3/23/2026 9:18:12 AM	00:00:25	5.5	5	5.5	4.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/23/2026 9:16:32 AM	3/23/2026 9:17:22 AM	00:00:50	5.2	6	6.5	5.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/23/2026 9:14:27 AM	3/23/2026 9:16:07 AM	00:01:40	4.9	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/23/2026 9:14:02 AM	3/23/2026 9:14:27 AM	00:00:25	5.9	5	5.5	4.5
EART TRAINING LAB	AstecEC10Incubator	CO2 Low	3/23/2026 9:13:37 AM	3/23/2026 9:14:02 AM	00:00:25	5.5	6	6.5	5.5
EART TRAINING LAB	AstecEC10Incubator	O2 High	3/23/2026 9:13:12 AM	3/23/2026 9:13:37 AM	00:00:25	5.8	5	5.5	4.5

Temp2

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp2	Sensor Communication Failure	3/26/2026 5:08:25 PM	3/26/2026 5:08:31 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp2	Sensor Communication Failure	3/26/2026 4:13:24 PM	3/26/2026 4:13:30 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp2	Sensor Communication Failure	3/26/2026 4:07:47 PM	3/26/2026 4:07:54 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp2	Sensor Communication Failure	3/26/2026 12:58:35 PM	3/26/2026 12:58:42 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp2	Sensor Communication Failure	3/25/2026 10:13:50 AM	3/25/2026 10:13:57 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp2	Sensor Communication Failure	3/24/2026 2:27:14 PM	3/24/2026 2:27:21 PM	00:00:07	NA	NA	NA	NA

Temp

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 5:58:37 PM	3/26/2026 5:58:43 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 5:54:24 PM	3/26/2026 5:54:31 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 5:41:48 PM	3/26/2026 5:41:54 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 5:08:25 PM	3/26/2026 5:08:31 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 4:52:32 PM	3/26/2026 4:52:38 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 4:31:35 PM	3/26/2026 4:31:36 PM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 4:13:29 PM	3/26/2026 4:13:30 PM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 4:10:47 PM	3/26/2026 4:10:51 PM	00:00:04	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 4:07:47 PM	3/26/2026 4:07:54 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 3:43:30 PM	3/26/2026 3:43:36 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 3:22:21 PM	3/26/2026 3:22:26 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 3:11:51 PM	3/26/2026 3:11:57 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 2:40:01 PM	3/26/2026 2:40:07 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 2:13:11 PM	3/26/2026 2:13:16 PM	00:00:05	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 1:55:04 PM	3/26/2026 1:55:10 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 1:46:38 PM	3/26/2026 1:46:45 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 1:28:26 PM	3/26/2026 1:28:32 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 1:09:42 PM	3/26/2026 1:09:43 PM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 12:58:35 PM	3/26/2026 12:58:42 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 12:46:36 PM	3/26/2026 12:46:38 PM	00:00:02	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 12:44:25 PM	3/26/2026 12:44:31 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 12:42:52 PM	3/26/2026 12:42:58 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 12:42:12 PM	3/26/2026 12:42:19 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 12:38:56 PM	1/9/2026 11:50:48 AM	-1824:-48:-08	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 11:47:38 AM	3/26/2026 11:47:44 AM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/26/2026 10:47:27 AM	3/26/2026 10:47:33 AM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:41:00 AM	NA	146:08:15	34.03	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:39:20 AM	3/26/2026 9:40:35 AM	00:01:15	34	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:33:56 AM	3/26/2026 9:38:30 AM	00:04:34	33.97	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:29:21 AM	3/26/2026 9:31:51 AM	00:02:30	33.93	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:28:06 AM	3/26/2026 9:28:56 AM	00:00:50	34.17	36	38.5	34.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:22:41 AM	3/26/2026 9:27:41 AM	00:05:00	34.07	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:21:01 AM	2/27/2026 5:03:22 PM	-640:-17:-39	34.07	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:14:46 AM	3/26/2026 9:15:11 AM	00:00:25	34.14	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:13:56 AM	3/26/2026 9:14:21 AM	00:00:25	34.47	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:13:06 AM	3/26/2026 9:13:31 AM	00:00:25	34.37	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/26/2026 9:11:26 AM	3/26/2026 9:11:51 AM	00:00:25	34.2	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 5:36:25 PM	3/25/2026 5:36:31 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 5:17:55 PM	3/25/2026 5:18:02 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 5:06:18 PM	3/25/2026 5:06:25 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 4:53:18 PM	3/25/2026 4:53:24 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 4:24:20 PM	3/25/2026 4:24:24 PM	00:00:04	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 4:22:17 PM	3/25/2026 4:22:24 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 4:06:27 PM	3/25/2026 4:06:34 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 3:58:06 PM	3/25/2026 3:58:13 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 3:51:51 PM	3/25/2026 3:51:58 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 2:41:50 PM	3/25/2026 2:41:57 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 2:36:15 PM	3/25/2026 2:36:22 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 2:13:14 PM	3/25/2026 2:13:17 PM	00:00:03	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 1:58:24 PM	3/25/2026 1:58:30 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 1:33:25 PM	3/25/2026 1:33:32 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 1:26:53 PM	3/25/2026 1:27:00 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 1:26:13 PM	3/25/2026 1:26:20 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 1:16:32 PM	3/25/2026 1:16:36 PM	00:00:04	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 1:03:12 PM	3/25/2026 1:03:19 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 1:00:53 PM	3/25/2026 1:00:59 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 12:31:53 PM	3/25/2026 12:32:00 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/25/2026 12:26:36 PM	3/26/2026 9:10:11 AM	20:43:35	33.83	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 11:51:54 AM	3/25/2026 11:52:01 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/25/2026 11:34:56 AM	3/25/2026 12:26:11 PM	00:51:15	33.53	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 11:31:56 AM	3/25/2026 11:32:03 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:57:51 AM	3/25/2026 11:06:16 AM	00:08:25	33.76	36	38.5	34.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:55:46 AM	3/25/2026 10:57:26 AM	00:01:40	33.76	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:52:01 AM	3/25/2026 10:55:21 AM	00:03:20	34.2	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 10:43:50 AM	3/25/2026 10:43:57 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:43:41 AM	3/25/2026 10:51:36 AM	00:07:55	34.24	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 10:26:35 AM	3/25/2026 10:26:41 AM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 10:20:13 AM	12/27/2025 3:54:05 PM	-2106:-26:-08	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:15:21 AM	3/25/2026 10:28:16 AM	00:12:55	34.07	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 10:15:14 AM	3/25/2026 10:15:21 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:13:57 AM	3/25/2026 10:14:57 AM	00:01:00	34.44	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/25/2026 10:13:50 AM	3/25/2026 10:13:57 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:13:16 AM	3/25/2026 10:13:41 AM	00:00:25	34.14	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:12:26 AM	3/25/2026 10:12:51 AM	00:00:25	34.27	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:11:11 AM	3/25/2026 10:12:01 AM	00:00:50	34.34	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/25/2026 10:10:21 AM	3/25/2026 10:10:46 AM	00:00:25	34.41	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 3:36:12 PM	3/24/2026 3:36:19 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 3:27:12 PM	3/24/2026 3:27:18 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 3:08:28 PM	3/24/2026 3:08:35 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 3:03:36 PM	3/24/2026 3:03:43 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 2:27:14 PM	3/24/2026 2:27:21 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 1:46:11 PM	3/24/2026 1:46:17 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 1:40:01 PM	3/24/2026 1:40:08 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 12:13:58 PM	3/24/2026 12:14:04 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 11:48:36 AM	3/24/2026 11:48:37 AM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 11:42:28 AM	3/24/2026 11:42:34 AM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 11:38:12 AM	3/24/2026 11:38:13 AM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 11:17:03 AM	3/24/2026 11:17:10 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 10:58:01 AM	3/24/2026 10:58:08 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 10:35:37 AM	3/24/2026 10:35:43 AM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 10:33:07 AM	3/24/2026 10:33:11 AM	00:00:04	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/24/2026 10:11:00 AM	3/25/2026 10:09:06 AM	23:58:06	33.56	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/24/2026 10:04:56 AM	3/24/2026 10:05:02 AM	00:00:06	NA	NA	NA	NA

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp	Temp Low	3/24/2026 10:03:05 AM	3/24/2026 10:10:35 AM	00:07:30	33.66	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/24/2026 9:58:06 AM	3/24/2026 10:02:40 AM	00:04:34	34.17	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 5:47:02 PM	3/23/2026 5:47:03 PM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 5:34:52 PM	3/23/2026 5:34:58 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 5:23:21 PM	3/23/2026 5:23:22 PM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 5:10:58 PM	3/23/2026 5:11:04 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 5:08:25 PM	3/23/2026 5:08:32 PM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 2:22:56 PM	3/23/2026 2:23:02 PM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 12:54:01 PM	3/23/2026 12:54:02 PM	00:00:01	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 12:50:39 PM	3/23/2026 12:50:43 PM	00:00:04	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 11:35:04 AM	3/23/2026 11:35:10 AM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 10:48:56 AM	3/23/2026 10:49:03 AM	00:00:07	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/23/2026 10:06:32 AM	3/24/2026 9:57:41 AM	23:51:09	33.83	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 10:02:47 AM	3/23/2026 10:06:07 AM	00:03:20	34.1	36	38.5	34.5
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 10:00:05 AM	3/23/2026 10:00:11 AM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Sensor Communication Failure	3/23/2026 9:43:16 AM	3/23/2026 9:43:22 AM	00:00:06	NA	NA	NA	NA
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:36:58 AM	3/23/2026 10:02:22 AM	00:25:24	33.83	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:30:17 AM	3/23/2026 9:36:33 AM	00:06:16	33.76	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:28:17 AM	3/23/2026 9:29:52 AM	00:01:35	34.14	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:26:07 AM	3/23/2026 9:27:47 AM	00:01:40	34.03	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:24:52 AM	3/23/2026 9:25:42 AM	00:00:50	33.9	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:22:22 AM	3/23/2026 9:24:27 AM	00:02:05	33.66	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:21:07 AM	3/23/2026 9:21:57 AM	00:00:50	34.2	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:19:27 AM	3/23/2026 9:20:17 AM	00:00:50	34.44	36	38.5	34.5
EART TRAINING LAB	Temp	Temp Low	3/23/2026 9:17:47 AM	3/23/2026 9:18:12 AM	00:00:25	34.44	36	38.5	34.5

Temp1

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp1	Temp High	3/26/2026 5:35:11 PM	3/26/2026 5:35:36 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 5:09:46 PM	3/26/2026 5:10:11 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 5:06:51 PM	3/26/2026 5:07:16 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 3:27:41 PM	3/26/2026 3:28:06 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 2:13:09 PM	3/26/2026 2:13:16 PM	00:00:07	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 2:08:31 PM	3/26/2026 2:08:56 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 1:55:09 PM	3/26/2026 1:55:10 PM	00:00:01	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 1:52:41 PM	3/26/2026 1:53:06 PM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 1:27:41 PM	3/26/2026 1:28:06 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 1:21:00 PM	3/26/2026 1:21:25 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 1:18:30 PM	3/26/2026 1:18:55 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 1:17:40 PM	3/26/2026 1:18:05 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 1:08:55 PM	3/26/2026 1:09:20 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 1:07:15 PM	1/12/2026 11:26:41 AM	-1753:-40:-34	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 12:46:26 PM	3/26/2026 12:46:32 PM	00:00:06	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 12:37:16 PM	3/26/2026 12:37:41 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 12:16:01 PM	3/26/2026 12:16:26 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 12:12:41 PM	3/26/2026 12:13:06 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 12:06:51 PM	3/26/2026 12:07:16 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 12:03:31 PM	3/26/2026 12:03:56 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 11:46:51 AM	3/26/2026 11:47:16 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 11:41:51 AM	3/26/2026 11:42:16 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 11:32:15 AM	3/26/2026 11:32:40 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 11:31:25 AM	3/26/2026 11:31:50 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 11:20:10 AM	3/26/2026 11:20:35 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 11:17:40 AM	3/26/2026 11:18:05 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 11:10:11 AM	3/26/2026 11:10:36 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/26/2026 10:53:06 AM	3/26/2026 10:54:21 AM	00:01:15	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:32:41 AM	3/26/2026 10:33:31 AM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:30:11 AM	3/26/2026 10:30:36 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:28:56 AM	3/26/2026 10:29:46 AM	00:00:50	37.53	37	37.5	36.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:27:16 AM	3/26/2026 10:27:41 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:22:16 AM	3/26/2026 10:22:41 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:21:26 AM	3/26/2026 10:21:51 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:19:21 AM	3/26/2026 10:20:11 AM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:18:06 AM	3/26/2026 10:18:31 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:14:46 AM	3/26/2026 10:15:11 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/26/2026 10:13:06 AM	3/26/2026 10:14:21 AM	00:01:15	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:12:16 AM	3/26/2026 10:12:41 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:11:26 AM	1/31/2026 12:39:25 PM	-1293:-32:-01	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:10:36 AM	3/26/2026 10:11:01 AM	00:00:25	37.56	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:08:56 AM	3/26/2026 10:09:21 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/26/2026 10:07:41 AM	3/26/2026 10:08:06 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/26/2026 10:06:01 AM	3/26/2026 10:07:16 AM	00:01:15	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/26/2026 10:03:06 AM	3/26/2026 10:05:36 AM	00:02:30	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/26/2026 9:34:46 AM	3/26/2026 10:02:41 AM	00:27:55	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 4:57:27 PM	2/27/2026 2:32:06 PM	-626:-25:-21	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 3:10:21 PM	3/25/2026 3:10:46 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 1:51:36 PM	3/25/2026 1:52:01 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 1:33:25 PM	3/25/2026 1:33:32 PM	00:00:07	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 1:26:22 PM	3/25/2026 1:26:36 PM	00:00:14	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 1:24:31 PM	3/25/2026 1:24:56 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:52:26 PM	3/25/2026 12:53:16 PM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:51:36 PM	3/25/2026 12:52:01 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:39:56 PM	3/25/2026 12:40:21 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:37:51 PM	3/25/2026 12:38:16 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:31:11 PM	3/25/2026 12:31:36 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:27:01 PM	3/25/2026 12:27:26 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:21:11 PM	3/25/2026 12:21:36 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:17:01 PM	3/25/2026 12:17:26 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 12:07:26 PM	3/25/2026 12:08:16 PM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:59:57 AM	3/25/2026 12:00:22 PM	00:00:25	37.5	37	37.5	36.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:43:16 AM	3/25/2026 11:43:41 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:28:41 AM	3/25/2026 11:29:06 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:26:11 AM	3/25/2026 11:26:36 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:22:01 AM	3/25/2026 11:22:26 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:18:16 AM	3/25/2026 11:18:41 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:16:11 AM	3/25/2026 11:16:36 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/25/2026 11:14:56 AM	3/25/2026 11:16:36 AM	00:01:40	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:12:51 AM	3/25/2026 11:13:16 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:11:36 AM	3/25/2026 11:12:01 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 11:09:56 AM	3/25/2026 11:10:21 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/25/2026 10:36:36 AM	3/25/2026 11:06:11 AM	00:29:35	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 10:35:46 AM	3/25/2026 10:36:11 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/25/2026 10:34:56 AM	3/25/2026 10:35:21 AM	00:00:25	37.56	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 5:28:31 PM	3/24/2026 5:28:56 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 4:03:31 PM	3/24/2026 4:03:56 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 3:03:43 PM	3/24/2026 3:03:55 PM	00:00:12	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 2:23:56 PM	3/24/2026 2:24:21 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 1:28:05 PM	3/24/2026 1:28:30 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 1:16:51 PM	3/24/2026 1:17:15 PM	00:00:24	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 1:06:01 PM	3/24/2026 1:06:51 PM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 1:01:26 PM	12/26/2025 1:24:30 PM	-2111:-36:-56	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 12:53:06 PM	3/24/2026 12:53:31 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 12:46:51 PM	3/24/2026 12:47:16 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 12:27:41 PM	3/24/2026 12:28:06 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 12:22:16 PM	3/24/2026 12:22:41 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:56:25 AM	3/24/2026 11:56:50 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:49:45 AM	3/24/2026 11:50:10 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:42:16 AM	1/10/2026 11:00:43 AM	-1752:-41:-33	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:41:01 AM	3/24/2026 11:41:51 AM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:30:11 AM	3/24/2026 11:30:36 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:25:36 AM	3/24/2026 11:26:01 AM	00:00:25	37.5	37	37.5	36.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:17:41 AM	3/24/2026 11:18:06 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:14:46 AM	3/24/2026 11:15:11 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:13:06 AM	3/24/2026 11:13:31 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:11:01 AM	3/24/2026 11:11:26 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:08:56 AM	3/24/2026 11:09:21 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:03:56 AM	3/24/2026 11:04:46 AM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:03:06 AM	3/24/2026 11:03:31 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 11:00:36 AM	3/24/2026 11:01:01 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:58:31 AM	3/24/2026 10:58:56 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:57:16 AM	3/24/2026 10:57:41 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:54:46 AM	3/24/2026 10:55:11 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:51:51 AM	3/24/2026 10:52:41 AM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:48:06 AM	3/24/2026 10:48:31 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:46:51 AM	3/24/2026 10:47:41 AM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:45:11 AM	3/24/2026 10:45:36 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/24/2026 10:43:31 AM	3/24/2026 10:44:46 AM	00:01:15	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:42:16 AM	3/24/2026 10:42:41 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:41:26 AM	3/24/2026 10:41:51 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:40:36 AM	3/24/2026 10:41:01 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:39:21 AM	3/24/2026 10:40:11 AM	00:00:50	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:37:16 AM	3/24/2026 10:38:06 AM	00:00:50	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/24/2026 10:08:30 AM	3/24/2026 10:36:51 AM	00:28:21	37.6	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/24/2026 10:06:50 AM	3/24/2026 10:07:15 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 5:42:22 PM	3/23/2026 5:42:47 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 5:28:12 PM	3/23/2026 5:28:37 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 5:14:52 PM	3/23/2026 5:15:17 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 2:46:32 PM	3/23/2026 2:46:57 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 1:31:12 PM	3/23/2026 1:31:32 PM	00:00:20	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 12:26:57 PM	3/23/2026 12:27:22 PM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 11:26:07 AM	3/23/2026 11:26:32 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 11:21:33 AM	3/23/2026 11:21:58 AM	00:00:25	37.5	37	37.5	36.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	Temp1	Temp High	3/23/2026 10:29:02 AM	3/23/2026 10:29:27 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 10:26:57 AM	3/23/2026 10:27:22 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 10:21:32 AM	3/23/2026 10:21:57 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 10:15:17 AM	3/23/2026 10:15:42 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 10:12:47 AM	3/23/2026 10:13:12 AM	00:00:25	37.53	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 10:11:07 AM	3/23/2026 10:11:32 AM	00:00:25	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/23/2026 10:08:37 AM	3/23/2026 10:10:17 AM	00:01:40	37.5	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High (Orange)	3/23/2026 9:39:53 AM	3/23/2026 9:40:42 AM	00:00:49	37.56	37	37.5	36.5
EART TRAINING LAB	Temp1	Temp High	3/23/2026 9:39:03 AM	3/23/2026 9:39:27 AM	00:00:24	37.5	37	37.5	36.5

ASNC02 Vaishala

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	ASNC02 Vaishala	CO2 High	3/26/2026 10:34:46 AM	3/26/2026 10:35:11 AM	00:00:25	6.5	6	6.5	5.5
EART TRAINING LAB	ASNC02 Vaishala	CO2 High (Orange)	3/26/2026 9:21:51 AM	3/26/2026 10:32:41 AM	01:10:50	6.51	6	6.5	5.5
EART TRAINING LAB	ASNC02 Vaishala	CO2 High	3/25/2026 11:37:01 AM	3/25/2026 11:37:26 AM	00:00:25	6.5	6	6.5	5.5
EART TRAINING LAB	ASNC02 Vaishala	CO2 High (Red)	3/25/2026 10:21:37 AM	3/25/2026 11:33:16 AM	01:11:39	6.51	6	6.5	5.5
EART TRAINING LAB	ASNC02 Vaishala	CO2 High	3/24/2026 11:05:11 AM	3/24/2026 11:05:36 AM	00:00:25	6.5	6	6.5	5.5
EART TRAINING LAB	ASNC02 Vaishala	CO2 High	3/24/2026 9:53:56 AM	1/8/2026 1:04:53 PM	-1796:-49:-03	6.52	6	6.5	5.5

ALARM & EVENTS

Hospital	Device	Message	Raised Time	Returned Time	Turnaround Time	Current Value	Set Limit	Upper Limit	Lower Limit
EART TRAINING LAB	ASNC02 Vaishala	CO2 High (Orange)	3/23/2026 9:25:42 AM	3/23/2026 10:26:32 AM	01:00:50	6.53	6	6.5	5.5

FDA Code 21 CFR Part 11 Compliance

Labcare is a truly “paperless” monitoring and recording service. All electronic records are fully FDA 21 CFR part 11 compliant and **securely stored on mirrored servers in two different geographical locations for up to 30 years.**

The service Labcare fully meets the exacting requirements of the FDA code which includes the use of unique electronic signatures specifically linked to operator names that are fully traceable. In addition our IT servers and databases are regulated and managed through the Company's ISO9001:2008 quality management system.

FDA 21 CFR part 11 specifically regulates the secure creation, storage and management of electronic temperature records, Instrument logs under a strict electronic signature policy that is the gold standard for data compliance in the field of monitoring systems.

Through our rigorous data security protocols, coupled with our 24/7 global data access via web-browser interfaces; our customers enjoy unprecedented data security, access and control of their monitoring processes.

Through our rigorous data security protocols, coupled with our 24/7 global data access via web-browser interfaces; our customers enjoy unprecedented data security, access and control of their monitoring processes.

Whenever electronic records are generated the importance of protecting the integrity, security and traceability of the records is critical to any business operating in a regulatory environment.

Since the publication by the FDA of 21 CFR part 11 code, electronic records and signatures can now be assumed to be equivalent to paper records and hand written signatures.

Due to the nature of the Labcare remote monitoring service, compliance with code 21 CFR part 11 is easily achieved as fundamentally all data records are stored and maintained securely at an off-site 'Cloud' location where system access to the records is securely managed.

Naturally the FDA code 21 CFR part 11 and subsequent issues of guidelines are open to interpretation. However, the key intention and requirements of this code are very clear.

It is the users responsibility to manage the usage of issue of electronic signatures, generated doc, However Shivani/ Labcare system will not be responsible for any perpetual tampering of data using a 3rd party software/ converter.

Labcare system access limited to authorized individuals via individual unique ID and password. However Shivani/ Labcare will not be responsible for user sharing the user related to credential with any other individual.

Labcare system user credential is binded to single system and user cannot log into other instrument or system until logged out. However user can opt out of this feature where Shivani/ Labcare system will not be responsible of any accidental accessing by any other user.

Labcare provides values of various parameter collected from different instrument through their communication protocol or parameters collected through various sensor and do not manipulate the data, but the data do not assure the unit to be working accurately as per standards, which need to be periodically verified by a Third party audit.

Labcare captures and stores the data, audit trails or reports for period of 3years only after which it will be deleted, but user can opt for higher retention period through by a subscription fee.

This white paper is intended to assist our existing and potential Labcare monitoring systems customers to satisfy themselves that the systems installed in their facilities are fully compliant with the FDA code.